QC-ABSTRACT

Name of Work:- Drilling of Borewells and Providing Water Supply in Ward No.17, BBMP, Bangalore

Sl No.	Item	Quantity As Per BOQ	Required No's of tests	Actual No's of tests	Tests
1	PCC 1:3:6	156.06 Cum	1	1	Cement
					Sand, Aggregates
2	M20	156.06 Cum	7	7	Concrete Cube Compressive Strength
3	CPVC Pipe 50mm	2264.00 M	1	1	-
4	CPVC Pipe 50mm	56.00 M	1	1	-

Cubes

0-5 m^3	1set
6-15 m^3	2set
16-30 m^3	3set
31-50 m^3	4 set

Add 1set for every 50 Cum

CIVIL ONE ENGINEERS & CONSULTANTS

Scanned with CamScanner